

AR6

REFERENCE REQUEST-FEDERAL RECORDS CENTERS

NOTE: Use a separate form for each request

SECTION I--TO BE COMPLETED BY REQUESTING AGENCY

ACCESSION NO.

412-03-0165

AGENCY BOX NUMBER

5 of 6

RECORDS CENTER LOCATION NUMBER

13123986

☒

BOX

18732



FOLDER (include file number and title)

REMARKS

FOIA REQUEST FOR KILTY BASKIN TX87726 Southwestern Electric Power

NATURE OF SERVICE

☐ FURNISH COPY OF
RECORD(S) ONLY☐ PERMANENT
WITHDRAWAL☐ TEMPORARY
LOAN OF RECORD(S)☐ REVIEW☐ OTHER
(Specify)

SECTION II - FOR USE BY RECORDS CENTER

☐ RECORDS NOT IN CENTER CUSTODY☐ RECORDS DESTROYED☐ WRONG ACCESSION NUMBER - PLEASE CHECK☐ WRONG BOX NUMBER - PLEASE RECHECK☐ WRONG CENTER LOCATION - PLEASE RECHECK☐ ADDITIONAL INFORMATION REQUIRED TO IDENTIFY RECORDS REQUESTED☐ MISSING (Neither record(s), information nor charge card found in container(s) specified)☐ RECORDS PREVIOUSLY CHARGED OUT TO (Name, agency and date):

REMARKS

Rec'd 7/19/18

DATE

SERVICE

TIME
REQUIREDSEARCHER'S
INITIALS

SECTION III - TO BE COMPLETED BY REQUESTING AGENCY

NAME OF REQUESTER

Gail Ann Noahubbi Plunkett

TELEPHONE NO.

214-665-6634

DATE

7/13/2018

RECEIPT OF RECORDS

US EPA, 6MD-II
Regional Records Manager
1445 Ross Ave., Suite 1200
Dallas, TX 75202Requester please sign, date and return this form, for file item(s), ONLY if the block
to right has been checked by the Records Center ☐

SIGNATURE

DATE



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 6
1445 ROSS AVENUE
DALLAS, TEXAS 75202-2733

OK

JUL 23 2003

CERTIFIED MAIL: RETURN RECEIPT REQUESTED (7001 0360 0003 6677 4123)

Mr. Curtis Seaton, Acting Manager
Wastewater Permitting Section (MC-148)
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, TX 78711-3087

Re: Approval
TPDES Permit No. TX0087726
Texas State Permit No. 02496
Southwestern Electric Power Company
Hallsville, TX 75650

Dear Mr. Seaton:

Thank you for the opportunity to review the draft proposed permit transmitted in the letter from Mr. Chris Linendoll (TCEQ) to Ms. Evelyn Rosborough (EPA) dated June 6, 2003, and received on June 9, 2003. As a result of our review, we conclude that the draft proposed permit appears to conform to the guidelines and requirements of the Clean Water Act.

Thank you for your cooperation. If we may help your office achieve its permitting goals, please call me at 214-665-7170 or have your staff contact Kilty Baskin at VOICE:214-665-7500, FAX:214-665-2191, or EMAIL:baskin.kilty@epa.gov.

Sincerely yours,

Paulette S. Johnsey
Acting Chief
Permits Branch

cc: Kimberly Wilson, Industrial Permits Section
Wastewater Permitting Section (MC 148)
TCEQ
P.O. Box 13087
Austin, Texas 78711-3087

bcc: KBASKIN (6WQ-PO)

READING FILE (6WQ-P)

EROSBORO (6WQ-CA)

RGIBSON (6EN-WC)

PERMIT FILE (TX0087726)

CONCURRENCES ORIG: KBASKIN (6WQ-PO) X7500 [July 23, 2003]

OFFICIAL FILE COPY

CODE: 6WQ-PO
NAME: CHOSCH
DATE: *July 23/03*

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

OFFICIAL USE

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Sent To

Street, Apt. No.,
or PO Box No.
City, State, ZIP+4

PS Form 3800, January 2001
See Reverse for Instructions

Postmark Here

7001 0360 0003 6677 4123

MEMORANDUM

DATE: July 22, 2003 **Previous Reviews:**

FROM: Mike Tillman, Permits Section (6WQ-PP)

TO: Kilty Baskin, Oversight Team (6WQ-PO)

SUBJECT: Southwestern Electric Power Co. - Pirkey Power Plant, TX0087726
Whole Effluent Toxicity (WET) Requirements

I have reviewed the file package submitted for the above referenced permit. The draft permit requirements for whole effluent toxicity appear to meet the minimum requirements for NPDES under the current TCEQ implementation procedures.

REQUIREMENTS:

None.

SUGGESTIONS:

None.

FINAL - I **DO** / do not concur (mt: 07/22/03), Permit conditions.

<u>Outfall</u>	<u>Species</u>	<u>Dur.</u>	<u>Frequency</u>	<u>CD</u>	<u>WET Limit?</u>
002	C. dubia	7D	1/6 Mos.	100%	No
	Fathead	7D	1/6 Mos.	100%	No

Due to ER

Robert J. Huston, *Chairman*

R. B. "Ralph" Marquez, *Commissioner*

Kathleen Hartnett White, *Commissioner*

Margaret Hoffman, *Executive Director*



Due to TCEQ

7.15.03

7.24.03

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

June 6, 2003

CERTIFIED MAIL

U.S. Environmental Protection Agency
Region 6
Attention: Evelyn Rosborough (6WQ-CA)
1445 Ross Avenue
Dallas, Texas 75202

Re: TPDES Draft Permit No. 02496 (TX0087726) - Southwestern Electric Power Co.

Dear Ms. Rosborough:

Enclosed is the draft permit and Fact Sheet and Executive Director's Preliminary Decision for the draft TPDES Permit No. 02496 as required under the TCEQ/EPA Memorandum of Agreement. Please review and provide any written comments, objections (general or interim) or recommendations with respect to the draft permit within forty-five days from receipt of this draft permit to my attention.

If you need additional information or have any questions, please contact Kimberly Wilson of my staff by telephone at (512) 239-4644, by E-mail at kwilson@tceq.state.tx.us, by fax at (512) 239-4430 or if by correspondence, include MC 148 in the letterhead address following the Permit Writer's name. Thank you for your cooperation in this matter.

Sincerely,

A handwritten signature in cursive script, appearing to read "Chris Linendoll".

Chris Linendoll, E.I.T., Team Leader
Industrial Permits
Wastewater Permitting Section
Water Quality Division

CL/kw

Enclosures

RECEIVED
2003 JUN -9 PM 2:22
6WQ-C
CUSTOMER SERVICE BRANCH



Doris White

06/11/03 02:48 PM

To: Kilty Baskin/R6/USEPA/US@EPA

cc:

Subject: Comments on TX Draft Permit TX0087726 - Southwestern Electric Power Co.

Comments for Total Selenium for Outfall 006, page 2g. *4 states higher selenium limits lasting 2 years, 364 days. 2 years would be 730 days, right?

*5 365 days from issuance - should be 730 days, right?

Page 12. 1. 2nd paragraph states "When an analysis of an effluent sample for these parameters results in a measurement of less than the MAL, that parameter shall be reported as "<(MAL value)" and this shall be interpreted as a value of zero (0) for compliance purposes. This MAL value is less than the Total Selenium limit for outfall 102, 202, 003, 004, and 006. Recommend changing the wording to readthat parameter shall be reported as "0" on the DMR.

Same with Copper MAL for outfall 202.

pg 16, 12.e. wording on no later than 2 years, 365 days should be changed to show 730 days. Also change wording in second paragraph.

page 2b, outfall 202

Please call me if you have any questions. Thanks.

Doris White

Environmental Protection Specialist